

Yolo-Solano Air Quality Management District
Daily Inspection Form for Retail Gasoline Dispensing Facilities
Questions Call (530) 757-3650 or toll-free (800) 287-3650

Employee Name: _____

Date: _____

Facility Name and Address: _____

Time: _____

Above-Ground & Underground Storage Tanks:

If a spill box is installed, is the spill box free of standing liquid, debris and other foreign matters? (underground)

Yes [] No []

Are fill tubes malfunctioning in any manner? (all)

Yes [] No []

Are fill tubes equipped with caps and are the caps in a closed position? (all)

Yes [] No []

Are dry breaks equipped with seals and are the caps in a closed position? (all)

Yes [] No []

Dispensing Equipment:

Are fueling instructions clearly displayed?

Yes [] No []

Are any dispenser hoses torn, flattened or crimped?

Yes [] No []

Are dispenser hoses the proper size and length?

Yes [] No []

For dispenser hoses equipped with retractors, are the hoses the proper loop height?

Yes [] No []

For the following nozzle components, are any:

Latching device springs missing or malfunctioning in any manner?

Yes [] No []

Vapor check valves missing or malfunctioning in any manner?

Yes [] No []

Spouts not the proper diameter or have holes that are plugged with debris?

Yes [] No []

Automatic shut-off mechanisms malfunctioning in any manner?

Yes [] No []

Hold open latches missing or malfunctioning in any manner?

Yes [] No []

Boots torn with a tear of 1" or more in length?

Yes [] No []

Boots torn in a triangular-shaped or similar tear 1/2" or more to a side?

Yes [] No []

Boots torn with a hole 1/2" or more in diameter?

Yes [] No []

For vacuum assist systems, is more than 1/4 of the flexible cone missing?

Yes [] No []

For balance systems, is more than 1/4 of the circumference (accumulated) of any faceplate damaged?

Yes [] No []

For vacuum assist systems, is the vapor processor operating properly (listen for vapor processor to turn on and off while refueling is occurring)?

Yes [] No []

I certify the foregoing information to be correct and complete to the best of my knowledge.

Inspection completed by: _____
(Signature)

Comments: _____

