



COMPLIANCE ADVISORY

GASOLINE DISPENSING FACILITIES

MAY 2015

This compliance advisory is intended to help inform businesses and the public understand changes to air pollution regulations or enforcement policies within the Yolo-Solano AQMD. Please contact staff with questions. See all advisories at ysaqmd.org/advisories.

REQUIREMENTS FOR GASOLINE DISPENSING FACILITIES

On January 14, 2015, Rule 2.22 was revised to allow certain exemptions to enhanced vapor recovery (EVR) requirements for gasoline dispensing facilities (GDFs) with aboveground storage tanks (ASTs), E85 fueling facilities and non-retail GDFs.

- ASTs installed and in operation before July 1, 2010, equipped with a previously certified vapor recovery system that complies with standing loss control (see below) and has a permitted throughput of less than 60,000 gallons per year is exempted from Phase I EVR requirements.
- E85 fueling facilities and non-retail GDFs that can demonstrate that at least 95% of the vehicles being fueled are equipped with Onboard Refueling Vapor Recovery (ORVR) are exempt from Phase II vapor recovery requirements. No action is required if your facilities meet these conditions.

REQUIREMENTS FOR STANDING LOSS CONTROL

All gasoline ASTs with a capacity of greater than 250 gallons will be required to meet SLC requirements effective **December 31, 2015**. Existing permit holders will not need to file a new Authority to Construct application to comply with these requirements. No action is required if your tank is already SLC-compliant.

- **ASTs installed BEFORE April 2009:** The tank must be certified under Air Resources Board (ARB) Executive Order VR-301-F. See <http://www.arb.ca.gov/vapor/eos/eo-vr301/eo-vr301.htm>.
- **ASTs installed DURING OR AFTER April 2009:** The tank must be certified under ARB Executive Order VR-302-F. See <http://www.arb.ca.gov/vapor/eos/eo-vr302/eo-vr302.htm>.

MORE INFO

- See Yolo-Solano AQMD Rule 2.2: <http://www.arb.ca.gov/DRDB/YS/CURHTML/R2-22.PDF>
- Questions? Contact Frank DeMaris at (530) 757-3667 or fdemaris@ysaqmd.org.